

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Monday, March 16, 2015
Partial Correction 1 Misc 1		NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP: 4" PVC DATACOM CONDUIT UNDER FOOTING @ SOUTH WALL + 10' INSIDE BUILDING;	
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Monday, March 16, 2015
Partial Correction 1 THE FOLLOWING AREAS ARE APPROVED		OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT + ROOF DRAIN PIPING: EAST OF ROOMS AE124 AND AE113; REMAINDER OF BUILDING TO WEST END	
		NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.	

Comments: