

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143142, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Passed	Wednesday, March 18, 2015

Comments: UNDER-SLAB ELECTRICAL CONDUIT INCLUDING THREE 4" PVC PIPES FOR POWER FROM UNDER GRADE BEAM @ SOUTH WALL TO ELECTRICAL ROOM; 4" DATACOM PIPE FROM ELECT ROOM TO UNDER GRADE BEAM AT NORTH WALL; 3/4" PVC STUBBED-UP AT SEVERAL ISLAND LOCATIONS @ WEST 1/2 OF BUILDING.