

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141079, Building Permit - Commercial
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Failed	Thursday, March 19, 2015

Corrective Action Required
1 FIRST FLOOR

ROUGH FRAMING CALLED IN-
1-2 FLOORS 3-19
NOT READY, ROCK IN THE WAY MISSING HOLD DOWNS AND NUTS ,
WINDOWS AND SHEETROCK IN THE WAY OF THE INSPECION.

Rough Framing Inspection - Commercial	Mark Harding	Partial	Thursday, March 19, 2015
--	--------------	---------	--------------------------

Corrective Action Required
1 Misc 1

- exterior shear wall inspection
1st, 2nd ,3rd.
- garage exterior hold down straps.
-

Comments: