

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Failed	Thursday, March 19, 2015

Corrective Action Required

1	FIRST FLOOR	exterior shear walls 1st & 2nd floor, Marcus Carrie Craver 03/18/2015 4:03 PM
		EXTERIOR SHEAR WALL NAIL PATTERN- FAILED, SOUTH SIDE APPROVED NORTH WALL FAILED

Comments: