

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

March 20, 2015

GUY GRONBERG ARCHITECTS
113 SE 3RD ST
LEES SUMMIT, MO 64063

Permit No: PRCOM20150471
Project Title: HURD FAMILY DENTAL
Project Address: 410D SE 3RD ST, Unit:102A, LEES SUMMIT, MO 64063
Parcel Number: 61230310300000000
Location: MOEHLE ACRES---LOT 3
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: DENTIST OFFICE EXPANDING INTO ADJACENT TENANT SPACE

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Excerpt from Sec. 7-130, Lees Summit Code of Ordinances.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of MEP contractors.

Building Plan Review

Reviewed By: Joe Frogge

Approved

Fire Plan Review

Reviewed By: Brian Austerman

Approved

1. 5306.2 Interior supply location.

Medical gases shall be stored in areas dedicated to the storage of such gases without other storage or uses. Where containers of medical gases in quantities greater than the permit amount are located inside buildings, they shall be in a 1-hour exterior room, a 1-hour interior room or a gas cabinet in accordance with Section 5306.2.1, 5306.2.2 or 5306.2.3,

CODES ADMINISTRATION

respectively. Rooms or areas where medical gases are stored or used in quantities exceeding the maximum allowable quantity per control area as set forth in Section 5003.1 shall be in accordance with the International Building Code for high-hazard Group H occupancies.

For information only. If medical gasses are stored in quantity this shall apply

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.