

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20142493, Public Works Infrastructure Permit - Residential
Tiffany Woods Storm Sewer Relocation
Address: 513 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Storm Sewer Construction Inspection	Jon Haley	Partial	Monday, March 23, 2015

Informational

1 Inspected storm run in front of house to downstream structure, and pipe to outlet. James asked if the homwowner could leave off flared end section. I asked Gene Williams and he said yes as long as toewall is poured. Calle djames and let him know.

PW-Erosion Sediment Control (ESC) Inspection	Jon Haley	Failed	Monday, March 23, 2015
---	-----------	--------	------------------------------

Corrective Action Required

1 Please clean the streets and keep them clean during construction.

Comments: