

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143105, Building Permit - Commercial  
Address: 2884 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Passed	Thursday, March 26, 2015

**Comments: OK TO COVER ALL WALLS AFTER ALL COPPER PIPING PENETRATIONS OF STEEL STUDS HAVE GROMMETS INSTALLED AND ALL JAMB STUDS ARE FULLY SCREWED TO BOTTOM TRACKS.**