

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Friday, March 27, 2015

Corrective Action Required

1	Misc 1	INWALL-PRE ROCK INSPECTION: GARAGE PLUMBING CHASE, SHOWER WALLS, FURNACE ROOM WALL GARAGE- IT &ELECT ROOM OK TO ONE SIDE 1ST- 2ND- 3RD- 4TH-
---	--------	---

Corrective Action Required

2	FRAMING/STRUCTURE	SOFIT CEILING OVER DECK/ BALCONYS 1ST FLOOR SOUTH SIDE 2ND FLOOR SOUTH SIDE FIRE CAULKING ON INTERIOR. OK TO COVER
---	-------------------	---

Corrective Action Required

3	Misc 1	covered canopies- firecaulking inside and out, no turn downs on vents and ducts. specify if you are caulking inside or outside, all turn downs must be complete. soffits ok to cover 1-2-3 floors
---	--------	--

Comments: