

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143272, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:103, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, March 31, 2015

Partial Correction
2 Misc 1

GWB AT NEWLY-BUILT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: B105; 106; 108; 114; 115; 121; 123; 124; CORRIDOR DOOR B114 RECESS

FIRE-CAULKING APPROVED AT SAME LOCATIONS EXCEPT COMPLETE AT PERIMETER OF ONE DAMPER AND STUFF SAFING ABOVE FLANGE OF ON EWF STEEL BEAM.

Comments: NOTED PLYWOOD SHEETS ON SITE FOR USE AS MOUNTING BOARDS FOR DATACOMM EQUIPMENT ARE FIRE-RESISTIVE.