

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141079, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Failed	Tuesday, March 31, 2015

### Corrective Action Required

1	Misc 1	1ST INSPECTION WALKED WITH NICK 2ND 3-25-15, WALKED WITH MACK, NEED TO SCREW 1ST FLOOR 4X4, 2ND, 7X7 WILL GO BACK 130PM. OK TO INSTALL 2ND LAYER OF ROCK TO THE 3RD FLOOR. NAIL PATTERN ON 2ND LAYER WILL BE 7/12  3-31- SOUTH STAIR NORTH WALL, 2ND LAYER NOT STAGGARED WITH 1ST LAYER FAILED
---	--------	---

### Comments: