

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## **Inspection Summary**

---

Permit #: PRCOM20150215, Building Permit - Commercial  
Address: 319 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:

**Rated Assembly  
Inspection**

Inspector:

John Borns

Outcome:

Partial

Date:

Wednesday, April 01, 2015

Partial Correction

1           Misc 1

OK TO TAPE, MUD AND FIRE-SEAL COLUMN WRAP AND LID RESTORATION AT:  
B.5/3 AFTER SCREW PATTERN IS IMPROVED TO UL SPEC;

**Comments:**