



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

April 03, 2015

TELECOM TOWERS LLC
PO BOX 723597
ATLANTA, GA 31139

Permit No: PRCOM20150657
Project Title: VERIZON KCYC SUMMIT WOODS
Project Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
Parcel Number: 51800040202000000
Location: GERBER HEIGHTS---UNNUMBERED TRACT IN SE 1/4 OF SEC-35 TWP-48 RNG-32
DAF: BEG AT NW COR SD 1/4 TH S 86 DEG E ALG N LI SD SE 1/4 535.33' TH S 4 DEG
W 21.3' TO POB SD PT ON S ROW OF I 470 HWY TH S 85 DEG E ALG SD ROW 556.29'
TH S 82 DEG E 15' MOL TH S 62 DEG 44 MIN 05 SEC E 217.61' TH S 77 DEG 51 MIN 54
SEC E 49.93' TO PT ON E LI NW 1/4 SE 1/4 TH S 2 DEG W 407' MOL TH N 85 DEG W
511.36' TH N 24 DEG W 579.75' TO TRU POB
Type of Work: NEW OTHER (COMMERCIAL)
Occupancy Group: UTILITY, MISCELLANEOUS
Description: EQUIPMENT SHELTER AND ELECTRICAL UPGRADES TO CELL TOWER SYSTEM

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Brian Austerman

Rejected

1. Will a new generator be set on this site? Plan information does not clearly show. If so provide generator specs to include fuel type and quantity of fuel storage

2. 2012 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

A knox box may be required if there is an automatic extinguishing system. Call (816) 969-1300 to obtain a knox box application

3. Provide specifications on the fire suppression system

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.