

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141072, Building Permit - Commercial  
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	Mark Harding	Partial	Tuesday, April 07, 2015

Corrective Action Required  
1 Misc 1

GAS PIPE INSPECITON-  
FROM BUILDING TO BBQ GRILL LOCATION, PIPE ONLY NO FIITINGS, NO  
CONNECTION TO STEEL PIPE, NO PRESSURE TEST.  
PARTIAL APPROVAL

**Comments:**