

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150215, Building Permit - Commercial
Address: 319 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, April 09, 2015
Partial Correction 1 Misc 1		OK TO TAPE, MUD AND FIRE-SEAL COLUMN WRAP AND LID RESTORATION AT: B.5/3 AFTER SCREW PATTERN IS IMPROVED TO UL SPEC;	
Partial Correction 2 Misc 1		OK TO COVER ELEMENTS OF TWO-LAYER COLUMN WRAP AS FOLLOWS: FIRST LAYER OF 5/8" TYPE X GWB AT B.5/6; B.5/13; B.5/18; B.5/21; B.5/24; B.5/25; B.5/3 COMPLETE	

Comments: