

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Thursday, April 09, 2015

Corrective Action Required

1	FIRST FLOOR	UNIT "D" INSTALL DUCT AND DAMPER FURNACE ROOM CEILING NEED ROCK AND TRAP LOWERED OR FLOOR CEILING ASSEMBLY LOWERED -SECURITY BLOCKING CORRIDOR WALLS - COMPLETE SHOWER TRAPS WHEN SHOWERS ARE INSTALLED. OK TO INSULATE 1ST FLOOR ONLY.
2	SECOND FLOOR	OK TO COVER WALLS AND CEILINGS AT 2ND FLOOR EXCEPT 1) LEAVE CEILINGS OPEN AT SHOWER TRAPS YET TO BE INSTALLED 2) BATH VENT FAN DUCTING AND DAMPERS SUBJECT TO APPROVAL BY MARK HARDING

Comments: