

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143105, Building Permit - Commercial  
Address: 2884 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Passed	Friday, April 10, 2015

<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Friday, April 10, 2015
---------------------------	--------------	---------	------------------------

Partial Correction  
1 Misc 1

TENANT OFFICE SPACE IN-WALL-OK TO ROCK

\*\*SPACE AT SW CORNER OF BUILDING: PROTECT PVC AND SUPPORT 3" PIPE  
AT MID-WALL

**Comments:**

**600 AMP METER FOR THE TENANT IS OK FOR RELEASE. 800 AMP SERVICE ALREADY APPROVED LAST  
TIME FOR THE WHOLE SHELL BUILDING**