

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143253, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:240, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Friday, April 10, 2015
Occupancy Inspection - Fire	Joe Dir	Passed	Friday, April 10, 2015
Alarm Test	Joe Dir	Passed	Friday, April 10, 2015

Comments: EXPANDED/RENOVATED AREA OK FOR USE AND OCCUPANCY AFTER SPARK RINGS ARE IN PLACE AT THREE ELECT RECEPES @ RECEPTION DESK AND PERMANENT PANEL SECHEDULES ARE IN PLACE AT AFFECTED PANELS SERVIING THIS DEPARTMENT AREA.