

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, April 10, 2015

Corrective Action Required

1	FIRST FLOOR	UNIT "D" INSTALL DUCT AND DAMPER FURNACE ROOM CEILING NEED ROCK AND TRAP LOWERED OR FLOOR CEILING ASSEMBLY LOWERED -SECURITY BLOCKING CORRIDOR WALLS - COMPLETE SHOWER TRAPS WHEN SHOWERS ARE INSTALLED. OK TO INSULATE 1ST FLOOR ONLY.
Partial Correction		
2	SECOND FLOOR	OK TO COVER WALLS AND CEILINGS AT: 2ND FLOOR 3RD FLOOR EXCEPT 1) LEAVE CEILINGS OPEN AT SHOWER TRAPS YET TO BE INSTALLED 2) BATH VENT FAN DUCTING AND DAMPERS SUBJECT TO APPROVAL BY MARK HARDING

Comments: