

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Failed	Monday, April 13, 2015

Corrective Action Required

1	FIRST FLOOR	EXTERIOR SHEAR WALL- FAILED SOUTHWALL FULL SHEET BOWED OUT AND NO NAILS. RECALL WHEN READY
---	-------------	--

Comments: