

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Failed	Monday, April 13, 2015

Partial Correction

1 Misc 1

SECOND LAYER OF FOR FIRST 3 FLOORS IN BOTH STAIRWELLS APPROVED

Partial Correction

2 B705 FIRE WALLS

ALL WALLS BEHIND SHOWERS APPROVED;
CORRIDOR CEILING-
ALL LEVELS FAILED, HOLES TO BIG , NOT CAULKED, NILLING SCREWS, AND
SCREW PATTERN
, NO BACKING AT ROCK SPLICES.

Corrective Action Required

3 FIRST FLOOR

Corrective Action Required

4 SECOND FLOOR

Corrective Action Required

5 THIRD FLOOR

Corrective Action Required

6 FOURTH FLOOR

Comments: