

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## **Inspection Summary**

---

Permit #: PRCOM20150215, Building Permit - Commercial  
Address: 319 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:

Inspector:

Outcome:

Date:

**Rated Assembly  
Inspection**

Partial Correction

1        Misc 1

OK TO TAPE, MUD AND FIRE-SEAL COLUMN WRAP AND LID RESTORATION  
AT: B.5/3 AFTER SCREW PATTERN IS IMPROVED TO UL SPEC;

Partial Correction

2        Misc 1

OK TO COVER ELEMENTS OF TWO-LAYER COLUMN WRAP AS FOLLOWS:  
FIRST LAYER OF 5/8" TYPE X GWB AT B.5/6; B.5/13; B.5/18; B.5/21; B.5/24;  
B.5/25;

B.5/3 COMPLETE

**Comments:**