

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Failed	Thursday, April 16, 2015

Corrective Action Required

1	Misc 1	1ST LAYER BUILDING #3- STAIR WALLS
		FAILED-NAILING ON EDGES OF ROCK, GAPS OVER 1/4" AT STAIR HEADERS. HOLES AND RIPS IN ROCL WITH STUD UNDER VISIBLE -3RD INSPECTION 4-16-15 NAIL PATTERN ON EDGE OF ROCK IS SPLICED IN SHEAT WALL. PROVIDE ENGINEERS REPORT OR INSTALL PER PLANS

Comments: