

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141214, Building Permit - Commercial
Address: 304 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mark Harding	Partial	Friday, April 17, 2015

Corrective Action Required

1	ELECTRICAL	PANEL- MDP ONLY OK TO RELEASE UFER GROUND UNDER PANEL /STEEL ABOVE AND TO THE WEST OF ELECTRICAL ROOM. PANELS- 1 2 3 4
---	------------	---

Comments: