

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141078, Building Permit - Commercial  
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Partial	Friday, April 17, 2015

Corrective Action Required

1	FIRST FLOOR	UNIT "D" INSTALL DUCT AND DAMPER FURNACE ROOM CEILING NEED ROCK AND TRAP LOWERED OR FLOOR CEILING ASSEMBLY LOWERED
---	-------------	---

Partial Correction

2	SECOND FLOOR	OK TO COVER WALLS AND CEILINGS AT 2ND FLOOR EXCEPT
---	--------------	--

Corrective Action Required

3	Misc 1	
---	--------	--

Corrective Action Required

4	THIRD FLOOR	OK TO ROCK UNITS AND WALLS TUB TRAPS INSPECTED
---	-------------	---

Corrective Action Required

5	LOWER LEVEL	
---	-------------	--

Corrective Action Required

6	FOURTH FLOOR	OK to rock ceiling only for mechanical drops and soffits
---	--------------	--

**Comments:**