

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143105, Building Permit - Commercial
Address: 2884 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Monday, April 20, 2015

Corrective Action Required

1 Misc 1

ABOVE-CEILING OK BELOW:
-SOUTH BIG ROOM AND TWO OFFICES

****SUPPORT MC AT MAXIMUM 6FT INTERVAL**

Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Passed	Monday, April 20, 2015
---	--------------	--------	------------------------

Comments:

PLUMBING FOR CLEANING SINK PLUMBING OUTSIDE OFFICE AREA-OK