

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150051, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:200, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Tuesday, April 21, 2015

Comments: OK TO COVER WHEN READY OPEN EXISTING WALLS AT BREAK ROOM AFTER:

- 1) DISIMILAR METAL PIPE CONTACTS ARE PROTECTED.**
- 2) ONE ELECTRICAL RECEPTACLE IS BACKED-UP.**
- 3) FLOOR OPENINGS ARE FIRE-BLOCKED.**

NO INSPECTION REQUIRED FOR FRAMING OF SMALL SOFFIT TO BE BUILT ABOVE WALL CABINET.