

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142004, Building Permit - Commercial
Address: 2884 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, April 22, 2015
Partial Correction			
1 ELECTRICAL		4 FRONT AND 3 REAR UNDERGROUND CONDUITS FOR LIGHT POLES OK.	
		-LP PIERS OK BELOW: 2 NE AND SE CORNER PIERS	

Comments: