

Temporary Certificate of Occupancy

Permit #: PRCOM20141072
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, April 22, 2015
Inspected By: Mark Harding
Expiration Date: 6/4/2015 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Wednesday, April 22, 2015

Corrective Action Required:

1 Misc 1 Clubhouse-
- provide Grippable handrails for stairs, provide 1 1/2" clearance on
west handrail to landing
-see other department comments for other outstanding issues
Approved for TCO- 4-22-15

Not included in this inspection, pool, gas line to grills, fence, pool
deck, pool shut off, etc.
building of club house structure only.