

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150427, Building Permit - Commercial  
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	John Borns	Passed	Wednesday, April 29, 2015
<b>Final Building Inspection - Commercial</b>	John Borns	Passed	Wednesday, April 29, 2015

**Comments: OK TO POUR WHEN READY FIVE 2' SQUARE x 3'-6" DEEP FOOTINGS FOR SHADE STRUCTURES WITH #6 BONDING CONDUCTORS FROM POST TO SLAB REINFORCING MESH AND GROUND ROD. FOUR #6 VERTICAL RE-BAR INSTEAD OF SIX PER DRAWING. CLOSE PERMIT.**