

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141079, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Failed	Wednesday, April 29, 2015

Corrective Action Required

1	FIRST FLOOR	1-4TH FLOOR PREROCK SHOWERS FAILED, SUPPORT TRUSS AT CUT PLATES, CAULK ALL PENETRATIONS TURN OUT CLEAN OUTS AT 1ST/GROUND FLOOR. TOILET WATER LINE PIPING TURNED IN WALL. RECALL WHEN READY
---	-------------	--

Comments: