



**LEE'S SUMMIT**  
**MISSOURI**



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20143105	Date:	April 30, 2015
Project Title:	F'REAL FOODS	Applicant:	
Location:	2884 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116
Type of Work:			
Occupancy Group:	MIX		
Description:	TENANT FINISH FOR NEW	Primary:	(913) 888-0647
OFFICE/WAREHOUSE			
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Brian Austerman**

**Released for Construction**

1. Plan review for adding in rack sprinklers
2. Modifications to existing systems involving 20 or more heads requires a hydrostatic test, call (816) 969-1300 to schedule

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**