

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, May 01, 2015
Partial Correction 2 Misc 1		OK TO COVER WHEN READY UNDER-SLAB PVC DWV PIPING AT: (A) TO (B.3) FROM (1.5) TO (6.8); BUILDING DRAIN FROM (6.8) SOUTH UNDER FOOTING; COMPLETE INCLUDING AT A124, 126 & 130 -- EXCEPT NOT READY AT RECOVERY A125;	
Partial Correction 3 Misc 1		DOMESTIC WATER SERVICE ENTRY TO BUILDING AT A125 IS 3" D.I. IN LIEU OF 2-1/2" COPPER PER DRAWINGS. RFI TO BE SUBMITTED TO CODES.	
Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, May 01, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT & FLOOR BOXES AT: 4 CONDUITS FROM NURSE STATION TO 16' NORTH; AT PAIN MANAGEMENT ROOMS A139-A142;	

Comments: