

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143454, Building Permit - Commercial
Address: 1317 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Failed	Friday, May 01, 2015

Corrective Action Required

1	Misc 1	VENTING FOR GREASE TRAP NEED CORRECTED- VENT AS PER PLANS AND WALL SINK CON NOT DRAIN INTO "WYE"
---	--------	---

Rough Electrical Inspection - Commercial	Mark Harding	Failed	Friday, May 01, 2015
---	--------------	--------	----------------------

Corrective Action Required

1	Misc 1	NEED ABOVE CEILING FOR ELECTRICAL AND PLUMBING
---	--------	--

Comments: