

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Tuesday, May 05, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC DWV PIPING AT: (A) TO (B.3) FROM (1.5) TO (6.8); BUILDING DRAIN FROM (6.8) SOUTH UNDER FOOTING; COMPLETE INCLUDING AT A124, 126, 130 AND **A125 -- WHERE 3" DUCTILE IRON WATER PIPE IS APPROVED FOR WATER SERVICE IN LIEU OF 2-1/2" TYPE K COPPER**

Comments: