

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141079, Building Permit - Commercial
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, May 05, 2015

Partial Correction

1	FIRST FLOOR	PRE ROCK AT SHOWER WALLS OK TO ROCK. ENSURE CLEANOUT OPENINGS ARE AT WALL SURFACE OR BY ACCESS PANEL. VARIATION ALLOWED AT 2104 AND 2110 ONLY TO REDUCE CLEANOUT ACCESS TO 2" TO MISS INTERFERING STUD.
---	-------------	--

TOILET WATER LINE PIPING TURNED IN WALL.

Partial Correction

2	SECOND FLOOR	PRE ROCK AT SHOWER WALLS OK TO ROCK
---	--------------	-------------------------------------

Partial Correction

3	THIRD FLOOR	PRE ROCK AT SHOWER WALLS OK TO ROCK
---	-------------	-------------------------------------

Comments: