

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150471, Building Permit - Commercial
Address: 410D SE 3RD ST, Unit:102A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Wednesday, May 06, 2015
Partial Correction 1 Misc 1		NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP AT 109, 110, 111;	
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Wednesday, May 06, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT 109, 110, 111; PIPING VARIATIONS FROM APPROVED DRAWING ARE TO BE SUBMITTED TO CODES ADMINISTRATION FOR RECORD. NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.	

Comments: