

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143272, Building Permit - Commercial  
Address: 200 NE MISSOURI RD, Unit:103, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Wednesday, May 06, 2015

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES:  
**FIRST FLOOR AREAS INCLUDING WAITING/COFFEE ROOM B100/B101**

THIRD FLOOR:

**- ENSURE ALL HVAC FLEX CONNECTORS ARE TAPED OR BANDED BOTH INNER AND OUTER LAYERS + INSTALL MINIMUM 1-1/2" WIDE STRAP HANGERS AT MAXIMUM 5' FLEX CONNECTOR INTERVALS.**

**Comments:**