

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141079, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Failed	Wednesday, May 06, 2015

Partial Correction

1	FIRST FLOOR	PRE ROCK AT SHOWER WALLS OK TO ROCK. ENSURE CLEANOUT OPENINGS ARE AT WALL SURFACE OR BY ACCESS PANEL. VARIATION ALLOWED AT 2104 AND 2110 ONLY TO REDUCE CLEANOUT ACCESS TO 2" TO MISS INTERFERING STUD.
		TOILET WATER LINE PIPING TURNED IN WALL.
		NOT READY

Partial Correction

2	THIRD FLOOR	PRE ROCK AT SHOWER WALLS OK TO ROCK
---	-------------	-------------------------------------

Partial Correction

3	FIRST FLOOR	PRE ROCK AT SHOWER WALLS OK TO ROCK
---	-------------	-------------------------------------

**Comments:**