

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150474, Building Permit - Commercial

Address: 600 SW JEFFERSON ST, Unit:300, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:301, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:203, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, May 07, 2015

Corrective Action Required

1 Misc 1

DEMO/REMOVALS: REMOVE ABANDONED MATERIALS

Corrective Action Required

2 Misc 1

BUCKET ABOVE CEILING MAY INDICATE PAST OR PRESENT ROOF LEAK. INVESTIGATE AND RESOLVE.

Corrective Action Required

3 Misc 1

ENSURE ALL CEILING SUPPORT WIRES EXTEND STRAIGHT FROM STRUCTURE ABOVE TO MAIN TEE.

Corrective Action Required

4 Misc 1

SMACNA / AIR DIFUSSION COUNCIL / MANUFACTURER'S INSTRUCTIONS > INSTALLATION OF HVAC FLEXIBLE DUCT AND INSULATION: SEE INSTRUCTION SHEET IN EACH BOX OF MATERIAL. CLAMPS & TAPING OF INNER AND OUTER LAYER MUST BE PER INSTRUCTIONS. NON-METALLIC CLAMPS OK ONLY WITH BEADED FITTINGS.

Corrective Action Required

5 Misc 1

NEC 300.11: SECURING AND SUPPORTING OF ELECTRICAL CABLE ASSEMBLIES: MAY NOT BE SUPPORTED BY CEILING SUPPORT HANGER WIRES; SUPPORT FROM STRUCTURE, FROM OTHER COMPONENTS OF ELECTRICAL SYSTEM, OR FROM HANGERS INSTALLED FOR SUPPORT OF THE ELECTRICAL SYSTEM. SECURE BOTH ENDS OF INDEPENDENT SUPPORT WIRES.

Corrective Action Required

6 Misc 1

NEC 334-10 SECURING / SUPPORT OF MC ELECTRICAL CABLE: SECURE WITHIN 12" OF BOXES AND SUPPORT AT 6' MAX INTERVALS THEREAFTER. COLORADO JIMS DO NOT SECURE MC TO RESIST TUGGING. USE CLAMPS THAT FASTEN MC IN PLACE WITHIN 12" OF BOX ENTRY.

Corrective Action Required

7 Misc 1

CLOSE ALL ELECTRICAL JUNCTION BOXES AND UNUSED JBOX OPENINGS

Corrective Action Required

8 Misc 1
Corrective Action Required
9 Misc 1
Corrective Action Required
10 Misc 1

ONE UNUSED MC CABLE WHIP TO BE SECURED WITH ENDS IN JBOX.

REMOVE TEMPORARY ELECTRICAL WIRING.

PLACEMENT / SUPPORT / SECURING OF LOW VOLTAGE ELECTRICAL CABLE:
ROUTE HIGH IN INTERSTITIAL SPACE \geq 18" ABOVE CEILING GRID; NOT TO BE
LAID LOOSE ON CEILING GRID; DROP TO TERMINATIONS WHERE LOCATED.
SUPPORT FROM STRUCTURE -- NOT FROM OTHER M/E/P SYSTEMS.

Comments: