

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Thursday, May 07, 2015
Partial Correction 1 Misc 1		-2nd LAYER LOWER LEVEL CORRIDOR CEILING SCREW ONLY -2ND LAYER SCREW LOWER LEVEL CORRIDOR WALLS -GARAGES 1,2,3 FIRST LAYER APPROVED -2ND LAYER LOWER LEVEL 2 HOUR CONDITONS ROOMS - EAST AND WEST TOWER 4TH FLOOR 4TH LAYER LID APPROVED -WALLS BETWEEN UNITS ONLY 4TH FLOOR	
Partial Correction 2 Misc 1		WALLS & CEILINGS @ 1ST FLR STORAGE ROOMS: GWB OK TO TAPE, MUD AND FIRE-SEAL. ALL FIRE SEALING AND FIRE ISOLATION OF PVC PIPE, ETC SUBJECT TO APPROVAL.	

Comments: