

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150474, Building Permit - Commercial

Address: 600 SW JEFFERSON ST, Unit:300, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:301, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:203, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, May 08, 2015

Corrective Action Required

11 Misc 1

CORRIDOR WALLS ARE REQUIRED TO MEET UL465. RE-INSPECTION REQUIRED FOR SEALING OF PENETRATIONS AND AT DOOR RECESS TO BE RATED ASSEMBLY. LEAVE TILE OUT ALONG CORRIDOR WALLS BOTH FACES. RATED ASSEMBLY AT DOOR RECESS MUST BE INSPECTED EACH LAYER -- WHETHER RATED LID OR WALLS TO DECK.

Comments: