

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150474, Building Permit - Commercial

Address: 600 SW JEFFERSON ST, Unit:300, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:301, LEES SUMMIT, MO 64063600 SW JEFFERSON ST, Unit:203, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, May 11, 2015

Corrective Action Required

1 Misc 1

3RD FLOOR: CORRIDOR WALLS ARE REQUIRED TO MEET UL465.  
RE-INSPECTION REQUIRED FOR SEALING OF PENETRATIONS AND AT DOOR RECESS TO BE RATED ASSEMBLY. LEAVE TILE OUT ALONG CORRIDOR WALLS BOTH FACES.

**NOT READY FOR RE-INSPECTION 5/11.**

Corrective Action Required

2 Misc 1

**OK TO COVER WHEN READY ABOVE CEILING SYSTEMS AT: 203-1;**

**Comments:**