

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141135, Building Permit - Commercial
Address: 3331 SW KESSLER DR, Unit:G1, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Monday, May 11, 2015

Corrective Action Required

1	Misc 1	- strap garage doors interior and exterior - nail pattern exterior of garage doors -install truss hangers front and rear framing inspection only
---	--------	---

Comments: