

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141138, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, Unit:G1, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Failed	Monday, May 11, 2015

Corrective Action Required

1	Misc 1	- strap garage doors interior and exterior - nail pattern exterior of garage doors - install truss hangers front and rear framing inspection only
---	--------	--

Comments: