

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Monday, May 11, 2015

Partial Correction
1 Misc 1

- 2nd LAYER LOWER LEVEL CORRIDOR CEILING SCREW ONLY
- 2ND LAYER SCREW LOWER LEVEL CORRIDOR WALLS
- GARAGES 1,2,3 FIRST LAYER APPROVED
- 2ND LAYER LOWER LEVEL 2 HOUR CONDITONS ROOMS
- EAST AND WEST TOWER 4TH FLOOR 4TH LAYER LID APPROVED
- WALLS BETWEEN UNITS ONLY 4TH FLOOR
elevator equipment room

Partial Correction
2 Misc 1

WALLS & CEILINGS @ 1ST FLR STORAGE ROOMS:
GWB OK TO TAPE, MUD AND FIRE-SEAL. ALL FIRE SEALING AND FIRE
ISOLATION OF PVC PIPE, ETC SUBJECT TO APPROVAL.

Comments: