

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141079, Building Permit - Commercial
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Monday, May 11, 2015

Corrective Action Required

1	FIRST FLOOR	units only- 2112 plate bolts, hold down, drilled truss dryer boxes 2110 -plate bolts, clean out laundry 2106- 2108 2104-dryer vents, bath fan, exterior stud drilled for exterior light replace or add 2102-install ground north wall hvac units 02;04;06
---	-------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required

2	SECOND FLOOR	units only--check all HVAC INCOMPLETE 2201-dryer vents , HVAC, 02-hvac tape joints 04 hold down not against top plate 06- drill joist sprinkler line 09-hvac 10- 11-line set caulk, driller holes in truss sprinkler line 12-angle wall rock, floor, support dwv
---	--------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required

3	THIRD FLOOR	
---	-------------	--

Corrective Action Required

4	FOURTH FLOOR	
---	--------------	--

Corrective Action Required

5	Misc 1	dryer boxes inspected 1-4 1st layer shower wall inspected 1st layer 2hr wall unit side inspected elevator ok to rock 1-3
---	--------	-----------------------------------------------------------------------------------------------------------------------------------

strap 4" roof drain 4th floor north stair .
-ALLROUGH
EXTERIOR GROUNDLEVEL SOFIT OK TO COVER.

Comments: