

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150850, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:R, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, May 12, 2015

Partial Correction

1	THE FOLLOWING AREAS ARE APPROVED	GRADE BEAMS AND PADS OK TO POUR AT THE FOLLOWING: -EAST LINE FROM H TO SE CORNER; FROM SE CORNER TO LINE 2  **THE EAST GRADE BEAM REBAR NOT PER PLAN **CLEAN OUT ALL LOOSE DIRT THAT FELL DOWN **PROVIDE MIN. 1.5" CLEARANCE FROM REBAR TO SOIL NEAR NE CORNER
---	----------------------------------	---

Comments: