

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141214, Building Permit - Commercial
Address: 304 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Wednesday, May 13, 2015

Corrective Action Required

1	FIRST FLOOR	WEST SIDE OF AUDITORIUM- FOLLOWING APPROVED TO COVER- 1HR CEILING OK TO COVER ROOMS :1024,225,26,27,28 CORRIDOR ,34,36,
---	-------------	--

Rated Assembly Inspection	Mark Harding	Partial	Wednesday, May 13, 2015
--------------------------------------	--------------	---------	-------------------------

Corrective Action Required

1	B705 FIRE WALLS	Rated columns- 1ST LAYER K.4,L6,N3, 2ND LAYER K4,L6,N3
---	-----------------	--

Comments: