



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

May 14, 2015

ACI BOLAND
1421 EAST 104TH ST; SUITE 100
KANSAS CITY, MO 64131

Permit No: PRCOM20151029
Project Title: SAINT LUKES HOSPITAL PRE-OP HOLDING ROOM
Project Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Parcel Number: 52440044000000000
Location: SAINT LUKES HOSPITAL OF LEES SUMMIT LOTS 1 & 2---LOT 1
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: INSTITUTIONAL, INCAPACITATED
Description: INTERIOR RENOVATION - REMODEL EXISTING OFFICE TO BECOME PRE-OP HOLDING ROOM WITHIN OPERATING ROOM DEPARTMENT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review	Reviewed By: Joe Frogge	Pending
Fire Plan Review	Reviewed By: Brian Austerman	Approved

1. Provide Med Gas Certifications

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.