

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141079, Building Permit - Commercial  
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Thursday, May 14, 2015

### Corrective Action Required

1	Misc 1	1ST INSPECTION WALKED WITH NICK 2ND 3-25-15, WALKED WITH MACK, NEED TO SCREW 1ST FLOOR 4X4, 2ND , 7X7 WILL GO BACK 130PM. OK TO INSTALL 2ND LAYER OF ROCK TO THE 3RD FLOOR. NAIL PATTERN ON 2ND LAYER WILL BE 7/12 3-31- SOUTH STAIR NORTH WALL, 2ND LAYER NOT STAGGARED WITH 1ST LAYER FAILED
---	--------	--

### Corrective Action Required

2	B717 CONCEALED SPACES	2HR RATED WALL- STAIR WALLS- ROOM SIDE :1ST LAYER OK-1-4 ;2ND LAYER OK1-4 1ST LAYER ELEVATOR 1-4 WALLS ONLY
---	-----------------------	--

### Comments: